## **Gardner**

## COMPRESSOR DATA SHEET

Denver Federal Uniform Test Method for Certain Air Compressors Not Applicable Compressor: Variable Frequency Drive

			L DATA - FOR				
1	Manufacturer: G	ardner Denver					
	Model Number PureAir TVS160-A125 (NA-IP55)				Date:	August 2024	
2	X Air-cooled Water-cooled				Type:	Scre	ew
	Oil Injected X Oil-Free				# of Stages:	s: <b>2</b>	
3*	Full Load Operating Pressure <sup>b</sup>				125	psig <sup>b</sup>	
4	Drive Motor Nominal Rating				200	hp	
5	Drive Motor Nominal Efficiency				95.3%	percent	
6	Fan Motor Nominal Rating (if applicable)				10.1	hp	
7	Fan Motor Nominal Efficiency				92.1%	percent	
	Input Power (kW)				Capacity (acfm) a,d	Specific Power (kW/100 acfm) <sup>d</sup>	
	180.1 Max				897	20.08	
8*	152.8				780	19.59	
	126.4				658	19.23	
	101.4				531	19.11	
	77.8				400	19.47	
	55.7 Min				265	21.00	
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>				0.0	kW	
10	30	200	400 Capa	600 city (ACFM)	800	1000	1200
	Note: Graph is only a visual representation of the data in section 8  Note: Y-axis scale 10 to 35, +5kW/100acfm increments if necessary above 35  X-Axis Scale, 0 to 25% over maximum capacity						

\* For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

NOTES: a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

- $b. \ \ The operating \ pressure \ at \ which \ the \ Capacity \ and \ Electrical \ Consumption \ were \ measured \ for \ this \ data \ sheet.$
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

ecific Energy Volume flow rate at specified conditions Volume Flow Rate Consumption Power ft<sup>3</sup>/min m<sup>3</sup>/min % % +/-7 Below 0.5 Below 17.6 +/-8 0.5 to 1.5 17.6 to 53 +/-6 +/-7 +/- 10% 1.5 to 15 53 to 529.7 +/-5 +/-6 Above 529.7 +/-4 Above 15

Member:

Member:

Compressed Air & Gas Institute

ROT 031.2

12/19 R3