Gardner

COMPRESSOR DATA SHEET

Denver Federal Uniform Test Method for Certain Air Compressors Not Applicable Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR				
1	Manufacturer: Gardner Denver			
	Model Number PureAir TVS160-A150 (NA-IP5	5) Date:	August 2024	
2	X Air-cooled Water-cooled	Туре	Screw	
	Oil Injected X Oil-Free	# of Stages:	2	
3*	Full Load Operating Pressure ^b	150	psig ^b	
4	Drive Motor Nominal Rating	200	hp	
5	Drive Motor Nominal Efficiency	95.3%	percent	
6	Fan Motor Nominal Rating (if applicable)	10.1	hp	
7	Fan Motor Nominal Efficiency	92.1%	percent	
8*	Input Power (kW)	Capacity (acfm) a,d	Specific Power (kW/100 acfm) ^d	
	178.0	Max 837	21.27	
	152.9	729	20.99	
	128.6	617	20.85	
	105.3	502	20.98	
	83.1	384	21.63	
	61.9	Min 264	23.47	
9*	Total Package Input Power at Zero Flow ^{c, d}	0.0	kW	
10	30 25 (kw/100VCFM) 20 10 0 200 400 66	0 800	1000 1200	
	Capacity (ACFM) Note: Graph is only a visual representation of the data in section 8 Note: Y-axis scale 10 to 35, +5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity			

^{*} For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator

 $Consult\ CAGI\ website\ for\ a\ list\ of\ participants\ in\ the\ third\ party\ verification\ program:$

www.cagi.org

NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.
- $b. \ \ The operating \ pressure \ at \ which \ the \ Capacity \ and \ Electrical \ Consumption \ were \ measured \ for \ this \ data \ sheet.$
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

ecific Energy Volume flow rate at specified conditions Volume Flow Rate Consumption Power ft³/min m³/min % % +/-7 Below 0.5 Below 17.6 +/-8 $0.5 \ to \ 1.5$ 17.6 to 53 +/-6 +/-7 +/- 10% 1.5 to 15 53 to 529.7 +/-5 +/-6 Above 529.7 Above 15 +/-4

Member:

Member:

Compressed Air & Gas Institute

ROT 031.2

12/19 R3